



ISTITUTO GIORDANO

CE NOTIFIED BODY No. 0407

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0407-CPR-1190 (IG-100-2016)

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction products

FACTORY MADE MINERAL WOOL PRODUCTS

identified as shown overleaf (Annex)

placed on the market by

DOUBLE EGRET THERMAL INSULATION CO., LTD.

NO.97 Liuquan Road, Zibo, Shandong, China (PRC)

and produced in the manufacturing plant

NO.97 Liuquan Road, Zibo, Shandong, China (PRC)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance at system 1 and the performances described in Annex ZA of the standard

EN 13162:2012

are applied and that

the products fulfil all the prescribed requirements.

This certificate was first issued on 07/06/2016 and will remain valid as long as the harmonised standard remains valid or the manufacturing conditions in the plant or the factory production control itself are not modified significantly.

Bellaria-Igea Marina - Italia, 07/06/2016

Revision No. 0

Firmato digitalmente da GIORDANO SARA LORENZA

CPD Department Technical Manager
(Dott. Ing. Giuseppe Persano Adorno)

Chief Executive Officer

(Dott. Arch. Sara Lorenza Giordano)

The original of this document consists of an electronic document with a digital signature affixed pursuant to DPR (Presidential Decree) 513/97.

Sheet 1of2

ANNEX TO CERTIFICATE

0407-CPR-1190 (IG-100-2016)

Revision No. 0 dated 07/06/2016

PRODUCT IDENTIFICATION			
Product name: CCEWOOL® ROCK WOOL BOARD Intended use: thermal insulation for buildings Apparent density: 100 kg/m ³ Nominal thickness range: 40 - 180 [mm]			
Characteristic	Test method	Value/level	Istituto Giordano test report
Reaction to fire (Euroclass)	EN ISO 1182:2002	A1	331154/9693/CPR
	EN ISO 1716:2002		331155/9694/CPR
	EN 13501-1:2007 + A1:2009		331156/9695/CPR

PRODUCT IDENTIFICATION			
Product name: CCEWOOL® ROCK WOOL BOARD Intended use: thermal insulation for buildings Apparent density: 150 kg/m ³ Nominal thickness range: 30 - 130 [mm]			
Characteristic	Test method	Value/level	Istituto Giordano test report
Reaction to fire (Euroclass)	EN ISO 1182:2002	A1	331169/9696/CPR
	EN ISO 1716:2002		331170/9697/CPR
	EN 13501-1:2007 + A1:2009		331171/9698/CPR